



CONTROL PANEL Make Datakom Model D100 MK2

The D100 MK2 is an Auto Start Control Module for single genset applications. It includes a backlit LCD display which clearly shows the status of the engine all the times. This module can either be programmed using the front panel or by using the Datakom Rainbow plus PC software.

Metering and Alarm indications:

- Generator frequency
- Underspeed, Overspeed
- Generator volts (L-L, L-N)
- Generator current
- Engine oil pressure
- Engine coolant temperature
- Fuel level (Warning or shutdown) Optional
- Hours run counter
- Battery volts
- Fail to start/stop
- Emergency stop
- Failed to reach loading voltage/frequency
- Charge fail
- Loss of magnetic pick-up signal Optional
- Low DC voltage
- CAN diagnostics and CAN fail/error

GENERATING SET MODEL (EY165)

 Output Ratings
 Prime
 Standby

 380-415 V, 3 ph, 50 Hz, 1500 rpm
 150 KVA
 165 KVA

 120 KW
 132 KW

Ratings at 0.8 Power Factor

| ENGINE / TECHNICAL DATA | |
|--------------------------------------|------------------------------------|
| Engine Make | YTO |
| Engine Model | LR6A3L-D |
| Governing Type | Electronic |
| Number of Cylinders | 6 |
| Cylinder Arrangement | Vertical in line |
| Bore and Stroke mm | 105X125 |
| Displacement / Cubic Capacity litres | 6.49 |
| Induction System | Turbo Charger |
| Cycle | 4 stroke |
| Combustion System | Direct Injection |
| DC Voltage | 24 |
| Rotation | Anti-clockwise, viewed on flywheel |
| Cooling System | Water - cooled |
| Engine Speed | 1500rpm |
| | |
| Engine Power kWm | 132 |
| Fuel Consumption @ 50% load L/hr | 15.47 |
| @ 75% load L/hr | 23.8 |
| @ 100% load L/hr | 34.748 |
| Fuel Tank Capacity: litres | 302 |
| | |
| | |

| ALTERNATOR DATA | |
|------------------------------------|-----------------------|
| Make | YANAN |
| Model | SLG274F |
| No. of bearings | 1 |
| Insulation class | Н |
| Total Harmonic Content | <3% |
| Wires | 6 |
| Ingress Protection | IP22 |
| Excitation System | SHUNT |
| Winding Pitch | 2/3 (wdg 3) |
| AVR Model | AS440 |
| Overspeed | 2250 mn ⁻¹ |
| Voltage Regulation (steady) | ±1% |
| Short Circuit Capacity | - |
| AREP Excitation System Available o | s Optional. |

| DIMENSIONS WITH CANOPY | |
|------------------------|------|
| Length mm | 3480 |
| Width mm | 1110 |
| Height mm | 1650 |





RATINGS DEFINITION

Prime Power

These ratings are applicable for supplying continuous electrical power (at variable load) in lieu of commercially purchased power. 10% overload power is available for 1 hour in 12 hours continuous operation.

Standby Power

These ratings are applicable for supplying continuous electrical power (at variable load) in the event of a utility power failure. No overload is permitted on these ratings.

STANDARD REFERENCE CONDITIONS

Output ratings are presented at 25°C air inlet temperature, barometric pressure 100 kPa, relative humidity 30%. This generating set is designed to operate at high ambient temperatures (up to 55°C), humidity (up to 99%) and higher altitudes.

De-ration may apply, please consult your dealer for specific site ratings.

Some of the specifications are not standard on all Genset models.

AVAILABLE OPTIONS & ACCESSORIES

We offer a range of optional features and accessories to tailor our generating sets to meet your power needs.

OPTIONS

- A variety of generating set control and synchronizing panels
- · Additional protection alarms and shutdowns
- · Water fuel seperator
- · Water jacket heater
- · Battery charger

ACCESSORIES

- Genuine spare parts
- · Load banks
- Auxiliary fuel tanks
- Manual & automatic transfer switches

STANDARD SPECIFICATIONS

ENGINE

YTO four stroke heavy duty high performance industrial type diesel

ENGINE FILTRATION SYSTEM

- Fuel filter Full flow lube oil filter
- All filters have replaceable elements.

3. COOLING RADIATOR

Radiator and cooling fan, complete with safety guards, designed to cool the engine at high ambient temperatures (consult your dealer

4. EXHAUST SYSTEM

Heavy duty Industrial Exhaust Silencer

5. CIRCUIT BREAKER TYPE

Legrand 3 pole MCB. (4 pole is optional)

6. FUEL SYSTEM

The baseframe design is incorporated with an integral fuel tank with a capacity of approx. 8 hours running at Full Load. The tank is supplied complete with fill cap breather, fuel feed and return lines to the Engine and drain plug.

7. ALTERNATOR 7.1 INSULATION SYSTEM

The insulation system is Class H

• All windings are impregnated in either a triple dip thermosetting liquid, oil and acid resisting polyester varnish or vacuum pressure impregnated with a Special polyester resin. Heavy coat of antitracking varnish additional protection against moisture or condensation

7.2 AUTOMATIC VOLTAGE REGULATOR (AVR) The fully sealed Automatic Voltage Regulator maintains the Voltage Regulation at $\pm 0.5\%$. Nominal adjustment by means of a trim not incorporated on the AVR.

7.3 MOTOR STARTING

An overload capacity equivalent to 300% of the Full Load impedance at zero Power Factor can be sustained for 10 seconds, when AREP option is fitted.

8. MOUNTING ARRANGEMENT 8.1 BASE FRAME

The complete Generating Set is mounted as a whole on a heavy duty fabricated steel Baseframe

8.2 COUPLING

The Engine and Alternator are directly coupled by means of an SAE flange. The Engine flywheel is flexibly coupled to the Alternator

8.3 ANTI-VIBRATION MOUNTING PADS

Anti-Vibration pads are affixed between the Engine / Alternator feet and the Baseframe thus ensuring complete vibration isolation of the rotating assembly.

8.4 SAFETY GUARDS

The Fan & Fan Drive along with the Battery Charging Alternator are Safety Guard protected for personnel protection.

9. FACTORY TESTS

The Generating set is load tested before dispatch
All protective devices control functions and site load conditions

are simulated. The generator and it's systems are checked before

10. EQUIPMENT FINISHING

All mild steel components are fully degreased and painted with powder coated paint to ensure maximum scuff resistance and durability.

11. DOCUMENTATIONS

Operation & Maintenance manual, Circuit wiring diagrams and Commissioning / Fault Finding instruction leaflets are accompanied with the Generator.

12. QUALITY STANDARDS

The equipment meets the following standards: BS4999, BS5000, BS5514 IEC 60034, VDE0530, NEMA MG 1.22 and ISO 8528.

13. WARRANTY

All of the Generating Sets are covered under a warranty policy for a period of 12 months. Warranty of the equipment is in line with manufacturers warranty terms & conditions. (check warranty statement for more details, as it may vary for different countries)

In line with continuous product development, we reserve the right to change specifications without notice.



JMG Limited marketing@jmglimited.com www.jmglimited.com